

Summary of Disciplinary Action

Accredited certifier	Disciplinary action no.	Property address	Details of disciplinary matter	Disciplinary action	Date of decision
Michael O'MALLEY BPB No. 0304	167	67-69 Pile Street MARRICKVILLE	The certifier issued a construction certificate for a development which was inconsistent with the development consent namely condition 28 which required a continuous accessible path of travel from the street frontage and vehicle parking area to the entry of the adaptable unit	Mr O'Malley was reprimanded and fined \$3000	23 May 2008