

Summary of Disciplinary Action

Accredited certifier	Disciplinary action no.	Complaint No.	Property address	Details of disciplinary matter	Disciplinary action	Date of decision
Thomas BOWDEN BPB No. 0042	410	25/13	4 Kallaroo Street, Mosman	 Failed to ensure that the stormwater system was connected to the Council's drainage pit at the street as per the drainage plan endorsed by the construction certificate. Failed to advise the applicants that the critical stage inspection for stormwater connections was not carried out by him or by another accredited certifier authorised by him. Failed to advise the applicants about correspondence from the Council related to the noncomplying stormwater system for the subject development. 	Mr Bowden was reprimanded	17/12/2015