

## Summary of Disciplinary Action

Accredited certifier	Disciplinary action no.	Complaint No. Property address	Details of disciplinary matter	Disciplinary action	Date of decision
William <b>NETTLETON</b>  BPB No. 0292	453	1-9 Beach Street, The Entrance	Issue of a construction certificate for a residential flat building which did not demonstrate compliance with each of the relevant BCA requirements (fire safety). Issued interim and final occupation certificates when the building was not suitable for occupation and use in accordance with its classifications under the BCA (fire safety).	Mr Nettleton was reprimanded and fined the sum of \$10,000.	1 February 2018