

Summary of Disciplinary Action

Accredited certifier	Disciplinary action no.	Property address	Details of disciplinary matter	Disciplinary action	Date of decision
Troy MYERS BPB No.0132	267	10 & 12 Holbeche Road Arndell Park	<ul style="list-style-type: none"> Mr Myers approved construction certificate drawings that depicted a development comprising external openings that did not comply with C3.2 and C3.4 of the Building Code of Australia in relation to protection from a fire source feature. Mr Myers approved construction certificate drawings that did not depict details relating to the provision of facilities for people with disabilities in accordance with the Building Code of Australia. 	Mr Myers was cautioned	18 February 2010