

Summary of Disciplinary Action

Accredited certifier	Disciplinary action no.	Property address	Complaint No.	Details of disciplinary matter	Disciplinary action	Date of decision
Paul LADOGNA BPB No. 0219	422	11 Phillips Street, Alexandria	47/15	Prior to issuing final occupation certificate, failed to ensure fire-rated linings (as shown on the development consent and construction certificate plans) within the dwelling's roof space along the side boundaries were installed.	Mr Ladogna was reprimanded and ordered to pay a fine of \$5,000.	3 May 2016