

## Summary of Disciplinary Action

Accredited certifier	Disciplinary action no.	Property address	Details of disciplinary matter	Disciplinary action	Date of decision
Glenn <b>FITZGIBBON</b>  BPB No. 0120	204	50 Eucumbene Avenue FLINDERS	<p>The certifier issued a complying development certificate for the construction of a pergola and BBQ with a total floor area of approximately 41sqm contrary to the requirements in Council's development control plan as the floor area of the pergola and BBQ exceeded 30sqm</p> <p>The certifier issued a complying development certificate in the absence of specifications of the development that describe the construction and materials of which the building is to be built and the method of drainage, sewerage and water supply in addition to details stating whether the materials used are new or second hand and the particulars of the materials to be used</p> <p>The certifier issued a complying development certificate where the estimation of the cost of works did not reflect the true and correct cost of the works</p>	Mr Fitzgibbon was reprimanded and fined \$500	5 Nov 2008