

Summary of Disciplinary Action

Accredited certifier	Disciplinary action no.	Complaint No.	Property address	Details of disciplinary matter	Disciplinary action	Date of decision
Nick Georgopoulos BPB No. 1925	447	84/16	56 Crawford Rd, Doonside	<ul style="list-style-type: none"> Issued a CDC without the plans being notated with the required BASIX measures. Building specification and a site inspection record was not forwarded to Council. Failed to ensure storm water drained to an approved disposal system and that a shed was demolished to ensure compliance with the CDC. 	Mr Georgopoulos is Cautioned	17 May 2017