

Summary of Disciplinary Action

Accredited certifier	Disciplinary action no.	Property address	Details of disciplinary matter	Disciplinary action	Date of decision
Anthony LEWIS BPB No. 0228	181	107 The Boulevard OAK FLATS	The certifier issued a complying development certificate for the construction of a swimming pool contrary to the requirements within Councils complying development control plan as it is located on land below the 1% Annual Exceedence Probability (AEP) Flood level plus 0.5m freeboard	Mr Lewis was reprimanded and report on practice	27 Jun 2008