

## Summary of Disciplinary Action

Accredited certifier	Disciplinary action no.	Property address	Details of disciplinary matter	Disciplinary action	Date of decision
Ken SMITH  BPB No. 0789	341	127 Mitchell Parade, Mollymook	Mr Smith issued a complying development certificate for a development that was not complying development under the Codes SEPP as it approved a balcony with an area larger than 12 square metres and more than 3 metres above the existing ground level.	Mr Smith was cautioned.	24 May 2012