

Summary of Disciplinary Action

Accredited certifier	Disciplinary action no.	Property address	Details of disciplinary matter	Disciplinary action	Date of decision
Glenn FITZGIBBON BPB No. 0120	333	6 Addison Street, Shellharbour	Mr Fitzgibbon issued a construction certificate when access was not provided to the building from the allotment boundary from the main point of entry (of the allotment boundary) in accordance with the requirements of Part D3, Access for People with Disabilities, of the Building Code of Australia.	Mr Fitzgibbon was reprimanded and fined the sum of \$3,000.	7 March 2012