

## Summary of Disciplinary Action

Accredited certifier	Disciplinary action no.	Property address	Details of disciplinary matter	Disciplinary action	Date of decision
Terry <b>WEST</b>  BPB No. 0438	133	182-184 Powderworks Road ELANORA HEIGHTS	The certifier issued a final occupation certificate in respect to a development that was not fit for occupation in accordance with its classification under the Building Code of Australia due to the manner in which the common wall was constructed between the ceiling and the roof of the building	Mr West was reprimanded and fined \$5000	8 Jun 2007