

Summary of Disciplinary Action

Accredited certifier	Disciplinary action no.	Property address	Details of disciplinary matter	Disciplinary action	Date of decision
Simon TRIVES BPB No. 0414	293	49 Wellington Street, Blacktown	<ul style="list-style-type: none"> The certifier issued a construction certificate for a factory building with ancillary offices and a car park that incorrectly classified the buildings. The certifier issued a fire safety schedule with the construction certificate that did not comply with the Environmental Planning and Assessment Regulation. The certifier issued an occupation certificate without the requisite fire safety schedule and fire safety certificate. The certifier issued a construction certificate and an amended construction certificate without the requisite building specification. 	Mr Trives was reprimanded and fined the sum of \$2000	14 Sept 2010