

## Summary of Disciplinary Action

Accredited certifier	Disciplinary action no.	Property address	Details of disciplinary matter	Disciplinary action	Date of decision
Paul <b>FITZGERALD</b>  BPB 0119	316	27-31 Billyard Avenue, Wahroonga.	<ul style="list-style-type: none"> <li>The certifier determined that the inspection of the stormwater drainage system was satisfactory when the stormwater drainage system for the development was not constructed in accordance with the approved plans.</li> <li>The certifier issued a final occupation certificate without ensuring a condition of consent in relation to certification of the stormwater system was complied with.</li> </ul>	Mr Fitzgerald was reprimanded and fined \$5000.00	25 August 2011