

Summary of Disciplinary Action

Accredited certifier	Disciplinary action no.	Complaint No.	Property address	Details of disciplinary matter	Disciplinary action	Date of decision
Peter Ruck BPB No. 0352	418	88/14	7 Shimmer Place, The Ponds	Mr Ruck in his role as principal certifying authority failed to require the person with the benefit of development consent to install fire safety screens to openable windows in accordance with the development consent.	1.Mr Ruck was reprimanded; 2. Mr Ruck was ordered to pay a fine of \$2,000 to the Board	15/01/16