

Summary of Disciplinary Action

Accredited certifier	Disciplinary action no.	Property address	Details of disciplinary matter	Disciplinary action	Date of decision
Ivan BOULLE BPB No. 0041	156	2, 4 and 6 Whiting Street ARTARMON	The certifier issued a construction certificate for the construction of a roof over an open-air roof-top car park. If the building works were to be erected in accordance with the construction certificate, the development would fail to meet the deemed-to-satisfy provisions of the Building Code of Australia concerning fire safety	Mr Boulle was reprimanded and fined \$5,500	13 Mar 2008